



(SECTIONAL VIEW)

Notes:

- INSULATION: Jet fire seal clips should be insulated.
- CERTIFICATION: Tested to J60 in accordance with HSE standard OTI 95 634 Lloyd's Register of Shipping, Certificate No. SAS F100065, Blast over-pressure to 1.35 bar g, Lloyd's Register of Shipping Certificate No. LWT 401087/1.
- MOVEMENT: Standard seal construction will accommodate +/-25mm in any plane.
- CLIPPING: Each seal is supplied with fitting instructions, adhesive and stainless steel worm drive clips to suit pipe and sleeve diameters. For diameters of 350mm and above 'double clipping' is required. The clipping length or cuff (B) is 50mm for single clips and 75mm for double clips.

Drawing Title:

STANDARD JETTEX PIPE PENETRATION  
FLEXIBLE SEAL SYSTEM J60



**MCL UNITEX LTD**  
MCL House, Adams Close,  
Heanor Gate Industrial Park,  
Heanor, Derbyshire,  
DE75 7SW  
United Kingdom  
Tel: +44 (0)1773 761226  
Fax: +44 (0)1773 711874  
Web: www.mclunitex.com

Rev	Date	Revision detail	Drn	Chk'd	App'd
B	02/06/10	Certification number revised	M.A.T.	J.D.	N.R.T.
A	04/08/09	Cuff clipping length change	G.F.	N.R.T.	I.C.K.
0	06/10/05	Drawing created	J.D.	N.R.T.	I.C.K.
Drawing Number					
PPS-0400					REV B